CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7165-1076:100 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Kidde-Fenwal, 400 Main Street, Ashland MA 01721

Contact: Terrill Garland (508) 881-2000 Fax *(508) 881-1773

DESIGN: Model GEMINI. Local; noncoded; automatic, manual, waterflow or releasing device service.

Refer to listee's data sheet for detailed product description and operational considerations.

System components:

295005 Control Board 295029 Voltmeter Kit 295003 Power Supply 295029 DC Ammeter 295004 Power Supply 295026 Relay

295009 Expansion Board 295024 EOL 295008 Auxiliary Relay

295006 Halon Control 295028 Digital Display 295007 Slave Board

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a control unit for use with separately listed compatible initiating and indicting

devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for

details.

XLF: 7165-1493:130

*Rev. 06-21-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 22, 2004 Date Issued: Listing Expires June 30, 2005

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager